

CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 45/17**

Test specification: **EN 1568-3: 2008**

Test report no.: **20170416 / Sth 237.1**

Requested by: **Bavaria Egypt, Block 109, Gisir El Suez St., Heliopolis Industrial Zone, Cairo
EGYPT**

Manufacturer: **Bavaria Egypt, Block 109, Gisir El Suez St., Heliopolis Industrial Zone, Cairo
EGYPT**

Name of the fire
extinguishing medium: **WHITE GHOST 3%**

Grade of foam concentrate: **Fluoroprotein foam concentrate (FP)
according to annex A EN 1568**

Test fire performance: **Extinguishing performance and burn-back resistance:
Low expansion foam according to EN 1568-3 (3%)
with potable water / with simulated sea water: **II A / II A****

Freezing point: **- 15 °C**

Notes: **—**


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

03 April 2017



Grad. Eng. Jürgen Dittrich
Laboratory Manager



MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX